



Product Service

# Attestation of Conformity

No. N8A 129618 0002 Rev. 00

**Holder of Attestation: AEG SOLAR ENERGY S.R.L.**

Sector 2, str. Delea Veche nr 24, Corp A, etaj 6, modul M1  
915400 Bucuresti  
ROMANIA

**Product:**

**Crystalline Silicon Terrestrial Photovoltaic  
(PV) Modules**  
**Mono-crystalline Silicon Photovoltaic  
Module**

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for conformity assessment. For details see: [www.tuvsud.com/ps-cert](http://www.tuvsud.com/ps-cert)

**Test report no.:** 882162433701

**Date,** 2024-12-10

( Xinlian LUO )

Page 1 of 2

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.



Product Service

# Attestation of Conformity

No. N8A 129618 0002 Rev. 00

## Model(s):

With half-cut (bifacial) N-type mono c-Si cell (under STC)  
 ALPS72D30-XXX/TP (XXX=570-610, in steps of 5, 144 cells)

ALPS66D30-XXX/TP (XXX=525-560, in steps of 5, 132 cells)

ALPS60D30-XXX/TP (XXX=475-510, in steps of 5, 120 cells)

ALPS54D30-XXX/TP (XXX=430-460, in steps of 5, 108 cells)

With half-cut (bifacial) N-type mono c-Si cell (under BNPI)

ALPS72D30-XXX/TP (XXX=632, 637, 643, 648, 654, 659, 665, 670, 676)

ALPS66D30-XXX/TP (XXX=576, 582, 587, 593, 598, 604, 609, 615, 620)

ALPS60D30-XXX/TP (XXX=521, 526, 532, 537, 543, 548, 554, 560, 565)

ALPS54D30-XXX/TP (XXX=465, 471, 476, 482, 488, 493, 499, 504, 510)

XXX is standing for rated output power in Wp

## Parameters:

Construction: Framed, with Junction box, Cable and Connectors

Test Laboratory: Yangzhou Opto-electrical Product Testing Institute  
 (10 Kaifa West Rd., Yangzhou, Jiangsu, P. R. China 225009)

Safety Class: Class II

Maximum System Voltage: 1500V DC

Fire Safety Class: Class C according to UL790

## Tested according to:

EN IEC 61730-1:2018  
 EN IEC 61730-2:2018  
 EN IEC 61730-1:2018/AC:2018-06  
 EN IEC 61730-2:2018/AC:2018-06

Page 2 of 2

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.